AMENDMENT OF SOLICITATION / MODIFICATION OF CONTRACT					1. CONT	RACT ID CODE	PAGE 1	OF PAGE
2. AMENDMENT/MODIFICATION NO. 0004	3. EFFECTIVE DATE 2008 09 02	ATE 4. REQUISITION/PURCHASE REQU				5. PROJECT N	O. (if applic	cable)
6. ISSUED BY	Code	7. AL	MINISTERED BY (II	other than	item 6)	Code		
Department of Homeland Security Federal Law Enforcement Training Procurement Division, Building 93 1131 Chapel Crossing Road Glynco, Georgia 31524	g Center	SEE	BLOCK 6					
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Co				1 4 7	9A. AMENDMENT OF SOLICITATION NO. HSFLGL08R00019			
			9B. DATED A(SEE ITEM 11) AUG 6, 2008					
					10A. MODIFICATION OF CONTRACT/ORDER NO.			
CODE	FACILITY CODE				10B. DATE	D (SEE ITEM 13)		
11. THIS ITEM ONLY APPLIES TO AMENDMENTS O					ITATIONS	3		
	ou desire to change an offer all likes reference to the solicitation DATA (if required) THIS ITEM APPLIES ONLY IT MODIFIES THE CONTRAPPLIES ONLY OF THE SUANT TO: (Specify authority) ACT/ORDER IS MODIFIED TO REFERENCE TO THE AUTHORITY OF FAR 43.	TO MOD ACT/ORD y) THE CHA FLECT THE 103(b).	mitted, such chang amendment, and is iFICATIONS OF GER NO. AS DESCURGES SET FORTH IT ADMINISTRATIVE C	e may be in received CONTRACCRIBED II	made by te prior to the CTS/ORD N ITEM 14 ARE MADE I	legram or letter, e opening hour an ERS, t. IN THE CONTRAC	provided end date spe	each telegram or ecified. O. IN ITEM 10A.
D. OTHER (Specify type of modification and authority)								
E. IMPORTANT: Contractor is not,	is required to sign this	document	and return	copies to	the issuing	office.		
14. DESCRIPTION OF AMENDMENT/ HSFLGL08R00019, TELE ENFORCEMENT TRAINING See page 2 for details of th Proposal due date remains	COMMUNICATIONS CENTER, GLYNCO is amendment.	S RO), GEOI	OM UPGF RGIA	RADE,	BLD	3 91, I	FEDER.	AL LAW
4:00 p.m. (EDT), September	r 15, 2008.							is are due
Except as provided herein, all terms and conditions of the document referenced in item 9A or 10 15A. NAME AND TITLE OF SIGNER (Type or print)			10A, as heretofore changed, remains unchanged and in full force and effect. 16A. NAME AND TITLE OF CONTRACTING OFFICE (Type or print) JoDeen Cuffe, Contracting Officer					
15B. CONTRACTOR/OFFEROR	15C. DATE SIG	GNED	16B. UNITED STA	TES OF A	MERICA		16C. DA	TE SIGNED
(Signature of person authorized to sign	7)		BY(Signature of	Contractin	ng Officer)			
NSN 7540-01-152-8070 PREVIOUS EDITION UNUSABLE		30-105		S		FORM 30 (REV. 10-8 GSA	13)	

Prescribed by GSA FAR (48 CFR) 53.243

BLOCK 14 CONTINUED

This amendment is issued to incorporate responses to contractor inquiries. The information is presented in Q&A format.

Q1. We would like clarification that Utility (GA Power) is providing material and labor for new primary cable and duct bank to new 500 transformer. We are clear that the scope includes material and labor for the rerouting of the feeder directly from the new transformer to building 91.

A1. Georgia Power is providing the transformer, pad, feed and the duct bank.

Q2. Is the existing floor in the data center a raised floor? If so, is it already grounded? Does it need to be grounded?

A2. Yes the data center has a raised floor and it is already grounded.

Q3. Are there any any alarm devices at the doors because there is a halon system in the room?

A3. No

Q4. The SK 1 drawing that is in our proposal package does not show this panel in the southwest corner of the building, it shows proposed MDF and ATS equipment in that area. Where does the 600 amp panel go?

A4. Same location

Q5. A.2-says to run 40a feeders to 2 existing CRAC units and 1 new CRAC unit. Plan views in our package don't seem to show all these CRAC units. Where on plan view are all three of these CRAC units located?

A5. Boiler Room

- Q6. A.4 & 5- which PDU on plan view is existing and which is new?
- A6. Racks one, two and three are existing and four is new.
- Q7. Reference section 6.A.1, Page 2 of the Statement of Work version 1.6, 7/21/08, states that there shall be a new junction box installed adjacent to new chiller for future ATS. Page 4, section 2.E, states that contractor shall provide, install and test a new 600 amp ATS. Please provide clarification. Is the intent to provide a new service rated ATS in front of the new 600 amp rated MDP?

A7. YES, required for the generator.

.

- Q8. Sketch 1 shows an indoor automatic transfer switch (ATS). In the generator specifications there is reference to a NEMA 3 ATS. Is the intent to install a NEMA 3 ATS indoors?
- A8. YES, it is shown on the drawing.
- Q9. Reference Question 6.A.3, page 2 in the Statement of Work. The referenced section specifies an over current protective device (OCD) of 100 amps. The specification for this unit recommends a 175 amp OCD. Please clarify the ampacity of the McQuay 75 ton chiller.